SIEMENS

Data sheet

6ES7511-1AK01-0AB0

WITH WORKING MEMORY 150 KB FOR PROGRAM AND 1 MB FOR DATA, 1. INTERFACE: PROFINET IRT WITH 2 PORT SWITCH, 60 NS BIT-PERFORMANCE, SIMATIC MEMORY CARD **NECESSARY**

SIMATIC S7-1500, CPU 1511-1 PN, CENTRAL PROCESSING UNIT



General information	
Product type designation	CPU 1511-1 PN
HW functional status	FS03
Firmware version	V2.0
Engineering with	
 STEP 7 TIA Portal configurable/integrated as of version 	V14
Configuration control	
via dataset	Yes
Display	
Screen diagonal (cm)	3.45 cm
Control elements	
Number of keys	6
Mode selector switch	1
Supply voltage	
Type of supply voltage	24 V DC
permissible range, lower limit (DC)	19.2 V

permissible range, upper limit (DC)	28.8 V
Reverse polarity protection	Yes
Mains buffering	100
Mains/voltage failure stored energy time	5 ms
Walle, voltage failure stored energy time	
Input current	
Current consumption (rated value)	0.7 A
Inrush current, max.	1.9 A; Rated value
² t	0.02 A ² ·s
Power	
Power consumption from the backplane bus	5.5 W
(balanced)	
Infeed power to the backplane bus	10 W
Power loss	
Power loss, typ.	5.7 W
Marray	
Memory Number of slots for SIMATIC memory card	1
SIMATIC memory card required	Yes
Work memory	
• integrated (for program)	150 kbyte
• integrated (for data)	1 Mbyte
Load memory	1 Mbyte
	32 Gbyte
Plug-in (SIMATIC Memory Card), max. Packup	32 Obyte
Backup maintenance-free	Yes
■ maintenance-iree	165
CPU processing times	
for bit operations, typ.	60 ns
for word operations, typ.	72 ns
for fixed point arithmetic, typ.	96 ns
for floating point arithmetic, typ.	384 ns
CPU-blocks	
Number of elements (total)	2 000; Blocks (OB, FB, FC, DB) and UDTs
DB	
Number range	1 60 999; subdivided into: number range that can be used by the user: 1 59 999, and number range of DBs created via SFC 86: 60 000 60 999
• Size, max.	1 Mbyte; For non-optimized block accesses, the max. size of the DB is 64 KB
FB	
Number range	0 65 535
• Size, max.	150 kbyte
FC	

Number range	0 65 535
• Size, max.	150 kbyte
ОВ	
• Size, max.	150 kbyte
Number of free cycle OBs	100
 Number of time alarm OBs 	20
 Number of delay alarm OBs 	20
 Number of cyclic interrupt OBs 	20; With minimum OB 3x cycle of 500 μs
 Number of process alarm OBs 	50
Number of DPV1 alarm OBs	3
 Number of isochronous mode OBs 	1
 Number of technology synchronous alarm OBs 	2
Number of startup OBs	100
 Number of asynchronous error OBs 	4
 Number of synchronous error OBs 	2
 Number of diagnostic alarm OBs 	1
Nesting depth	
• per priority class	24
Counters, timers and their retentivity	
S7 counter	
Number	2 048
Retentivity	
— adjustable	Yes
IEC counter	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
S7 times	
Number	2 048
Retentivity	
— adjustable	Yes
IEC timer	
Number	Any (only limited by the main memory)
Retentivity	
— adjustable	Yes
Data areas and their retentivity Flag	
• Number, max.	16 kbyte
Number, max. Number of clock memories	8; 8 clock memory bits, grouped into one clock memory byte
Data blocks	c, a clock memory bite, grouped into one clock memory byte
Retentivity adjustable	Yes
. Colonianty dejudicable	

. 5	Ma
Retentivity preset	No
Local data	CA librator many AC I/D a callilla all
• per priority class, max.	64 kbyte; max. 16 KB per block
Address area	
Number of IO modules	1 024; max. number of modules / submodules
I/O address area	
• Inputs	32 kbyte; All inputs are in the process image
Outputs	32 kbyte; All outputs are in the process image
per integrated IO subsystem	
— Inputs (volume)	8 kbyte
Outputs (volume)	8 kbyte
per CM/CP	
— Inputs (volume)	8 kbyte
— Outputs (volume)	8 kbyte
Subprocess images	
Number of subprocess images, max.	32
Hardware configuration Number of distributed IO systems	32; A distributed I/O system is characterized not only by the
Number of distributed to systems	integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link)
Number of DP masters	
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Number of IO Controllers	
• integrated	1
• Via CM	4; A maximum of 4 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total
Rack	
Modules per rack, max.	32; CPU + 31 modules
 Number of lines, max. 	1
PtP CM	
Number of PtP CMs	the number of connectable PtP CMs is only limited by the number of available slots
Time of day	
Clock	
• Type	Hardware clock
Backup time	6 wk; At 40 °C ambient temperature, typically
 Deviation per day, max. 	10 s; Typ.: 2 s
Operating hours counter	
Number	16
Clock synchronization	

• supported	Yes
• in AS, master	Yes
• in AS, slave	Yes
• on Ethernet via NTP	Yes

in Ao, master	1.00
• in AS, slave	Yes
on Ethernet via NTP	Yes
Interfaces	
Interfaces Number of PROFINET interfaces	1
Trainibol of Free live Findendoos	·
1. Interface	
Interface types	
 Number of ports 	2
integrated switch	Yes
• RJ 45 (Ethernet)	Yes; X1
Functionality	
 PROFINET IO Controller 	Yes
PROFINET IO Device	Yes
SIMATIC communication	Yes
Open IE communication	Yes
• Web server	Yes
Media redundancy	Yes
PROFINET IO Controller	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	Yes
 Open IE communication 	Yes
— IRT	Yes
— MRP	Yes; As MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
— PROFlenergy	Yes
— Prioritized startup	Yes; Max. 32 PROFINET devices
— Number of connectable IO Devices, max.	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
 Number of connectable IO Devices for RT, 	128
max.	
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on
opading into	communication share set for DDOCINET IO on the number of IO

communication share set for PROFINET IO, on the number of IO $\,$

devices, and on the quantity of configured user data

Update time for IRT	
— for send cycle of 250 μs	250 µs to 4 ms; Note: In the case of IRT with isochronous mode,
	the minimum update time of 625 μs of the isochronous OB is decisive
— for send cycle of 500 μs	500 μ s to 8 ms; Note: In the case of IRT with isochronous mode, the minimum update time of 625 μ s of the isochronous OB is decisive
— for send cycle of 1 ms	1 ms to 16 ms
— for send cycle of 2 ms	2 ms to 32 ms
— for send cycle of 4 ms	4 ms to 64 ms
 With IRT and parameterization of "odd" send cycles 	Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s 3 875 μ s)
Update time for RT	
— for send cycle of 250 μs	250 μs to 128 ms
— for send cycle of 500 μs	500 μs to 256 ms
— for send cycle of 1 ms	1 ms to 512 ms
— for send cycle of 2 ms	2 ms to 512 ms
— for send cycle of 4 ms	4 ms to 512 ms
PROFINET IO Device	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	No
Open IE communication	Yes
— IRT	Yes
— MRP	Yes
— MRPD	Yes; Requirement: IRT
— PROFlenergy	Yes
— Shared device	Yes
 Number of IO Controllers with shared 	4
device, max.	
Interface types	
RJ 45 (Ethernet)	
• 100 Mbps	Yes
 Autonegotiation 	Yes
Autocrossing	Yes
 Industrial Ethernet status LED 	Yes
Protocols	
Number of connections	
Number of connections, max.	96; via integrated interfaces of the CPU and connected CPs / CMs
 Number of connections reserved for ES/HMI/web 	10

 Number of connections via integrated interfaces 	64
 Number of S7 routing paths 	16
ROFINET IO Controller	
Services	
— PG/OP communication	Yes
— S7 routing	Yes
— Isochronous mode	Yes
— Open IE communication	Yes
— IRT	Yes
— MRP	Yes; As MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50
— MRPD	Yes; Requirement: IRT
— PROFlenergy	Yes
— Prioritized startup	Yes; Max. 32 PROFINET devices
— Number of connectable IO Devices, max.	128; In total, up to 256 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET
— Of which IO devices with IRT, max.	64
 Number of connectable IO Devices for RT, max. 	128
— of which in line, max.	128
 Number of IO Devices that can be simultaneously activated/deactivated, max. 	8; in total across all interfaces
— Number of IO Devices per tool, max.	8
— Updating times	The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data
IMATIC communication	
S7 communication, as server	Yes
S7 communication, as client	Yes
User data per job, max.	See online help (S7 communication, user data size)
pen IE communication	
• TCP/IP	Yes
— Data length, max.	64 kbyte
 several passive connections per port, supported 	Yes
• ISO-on-TCP (RFC1006)	Yes
— Data length, max.	64 kbyte
• UDP	Yes
— Data length, max.	1 472 byte
• DHCP	No
• SNMP	Yes
• DOD	Voo

• DCP

Yes

• LLDP	Yes
Web server	
• HTTP	Yes; Standard and user pages
• HTTPS	Yes; Standard and user pages
OPC UA	
OPC UA Server	Yes; Data access (read, write, subscribe), runtime license required
 Application authentication 	Yes
— Security policies	Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256
 User authentication 	"anonymous" or by user name & password
Further protocols	
• MODBUS	Yes; MODBUS TCP
Media redundancy	
Switchover time on line break, typ.	200 ms; For MRP, bumpless for MRPD
 Number of stations in the ring, max. 	50
Isochronous mode	Very With religious OD Or male of COT us
Isochronous operation (application synchronized up to terminal)	Yes; With minimum OB 6x cycle of 625 μs
Equidistance	Yes
S7 message functions	
Number of login stations for message functions, max.	32
Block related messages	Yes
Number of configurable alarms, max.	5 000
Number of configurable alarms, max. Number of simultaneously active alarms in alarm pool	5 000
Number of simultaneously active alarms in alarm	5 000 300
Number of simultaneously active alarms in alarm pool	
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system	300
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control	300 100
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects	300 100
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions	300 100 80 Yes; Parallel online access possible for up to 5 engineering
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions Joint commission (Team Engineering)	300 100 80 Yes; Parallel online access possible for up to 5 engineering systems
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions Joint commission (Team Engineering)	300 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step	300 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients)
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Status/control	300 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No
Number of simultaneously active alarms in alarm pool Number of reserved user alarms Number of reserved alarms for system diagnostics Number of reserved alarms for Motion Control technology objects Test commissioning functions Joint commission (Team Engineering) Status block Single step Status/control Status/control variable	300 100 80 Yes; Parallel online access possible for up to 5 engineering systems Yes; Up to 8 simultaneously (in total across all ES clients) No Yes Inputs/outputs, memory bits, DBs, distributed I/Os, timers,

— of which control variables, max.	200; per job
Forcing	
• Forcing, variables	Peripheral inputs/outputs
Number of variables, max.	200
Diagnostic buffer	
• present	Yes
Number of entries, max.	1 000
— of which powerfail-proof	500
Traces	***
Number of configurable Traces	4; Up to 512 KB of data per trace are possible
Interrupts/diagnostics/status information	
Diagnostics indication LED	
• RUN/STOP LED	Yes
• ERROR LED	Yes
MAINT LED	Yes
 Connection display LINK TX/RX 	Yes
Supported technology objects	
Motion Control	Yes; Note: The number of axes affects the cycle time of the PLC
	program; selection guide via the TIA Selection Tool or SIZER
 Number of available Motion Control resources 	800
for technology objects (except cam disks)	
 Required Motion Control resources 	
per speed-controlled axis	40
— per positioning axis	80
— per synchronous axis	160
per external encoder	80
— per output cam	20
— per cam track	160
— per probe	40
 Positioning axis 	
 Number of positioning axes at motion control cycle of 4 ms (typical value) 	5
 Number of positioning axes at motion control cycle of 8 ms (typical value) 	10
Controller	
PID_Compact	Yes; Universal PID controller with integrated optimization
PID_3Step	Yes; PID controller with integrated optimization for valves
PID-Temp	Yes; PID controller with integrated optimization for temperature
Counting and measuring	
High-speed counter	Yes

Ambient conditions

Ambient temperature during eneration	
Ambient temperature during operation	0 °C
horizontal installation, min.horizontal installation, max.	60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off
• vertical installation, min	0 °C
vertical installation, min.vertical installation, max.	40 °C; Display: 40 °C, at an operating temperature of typically 40
	°C, the display is switched off
Ambient temperature during storage/transportation	
• min.	-40 °C
• max.	70 °C
Configuration	
Programming	
Programming language	
— LAD	Yes
— FBD	Yes
— STL	Yes
— SCL	Yes
— GRAPH	Yes
Know-how protection	
User program protection	Yes
Copy protection	Yes
Block protection	Yes
Access protection	
Password for display	Yes
 Protection level: Write protection 	Yes
 Protection level: Read/write protection 	Yes
 Protection level: Complete protection 	Yes
Cycle time monitoring	
• lower limit	adjustable minimum cycle time
• upper limit	adjustable maximum cycle time
Dimensions	
Width	35 mm
Height	147 mm
Depth	129 mm
Weights	
Weight, approx.	430 g

last modified:

12/06/2016