

SIMATIC S7-1500F, CPU 1518F-4 PN/DP ODK, CENTRAL PROCESSING UNIT WITH SIMATIC S7-1500F, WORKING MEMORY 6 MB FOR PROGRAM AND 20 MB FOR DATA, 1. INTERFACE: PROFINET IRT WITH 2 PORT SWITCH, 2. INTERFACE: PROFINET RT, 3. INTERFACE: ETHERNET, 4. INTERFACE: PROFIBUS, 1 NS BIT-PERFORMANCE, SIMATIC MEMORY CARD NECESSARY



| General information | |
|---|-----------------------|
| Product type designation | CPU 1518F-4 PN/DP ODK |
| Firmware version | V2.0 |
| Engineering with | |
| <ul style="list-style-type: none"> STEP 7 TIA Portal configurable/integrated as of version | V14 |
| Configuration control | |
| via dataset | Yes |
| Display | |
| Screen diagonal (cm) | 6.1 cm |
| Control elements | |
| Number of keys | 6 |
| Mode selector switch | 1 |
| Supply voltage | |
| Type of supply voltage | 24 V DC |
| permissible range, lower limit (DC) | 19.2 V |
| permissible range, upper limit (DC) | 28.8 V |

| | |
|---|---|
| Reverse polarity protection | Yes |
| Mains buffering | |
| • Mains/voltage failure stored energy time | 5 ms |
| Input current | |
| Current consumption (rated value) | 1.55 A |
| Inrush current, max. | 2.4 A; Rated value |
| I^2t | 0.02 A ² ·s |
| Power | |
| Power consumption from the backplane bus (balanced) | 30 W |
| Infeed power to the backplane bus | 12 W |
| Power loss | |
| Power loss, typ. | 24 W |
| Memory | |
| Number of slots for SIMATIC memory card | 1 |
| SIMATIC memory card required | Yes |
| Work memory | |
| • integrated (for program) | 6 Mbyte |
| • integrated (for data) | 20 Mbyte |
| • Integrated (for ODK application) | 20 Mbyte |
| Load memory | |
| • Plug-in (SIMATIC Memory Card), max. | 32 Gbyte |
| Backup | |
| • maintenance-free | Yes |
| CPU processing times | |
| for bit operations, typ. | 1 ns |
| for word operations, typ. | 2 ns |
| for fixed point arithmetic, typ. | 2 ns |
| for floating point arithmetic, typ. | 6 ns |
| CPU-blocks | |
| Number of elements (total) | 10 000; Blocks (OB, FB, FC, DB) and UDTs |
| DB | |
| • Number range | 1 ... 60 999; subdivided into: number range that can be used by the user: 1 ... 59 999, and number range of DBs created via SFC 86: 60 000 ... 60 999 |
| • Size, max. | 16 Mbyte; For non-optimized block accesses, the max. size of the DB is 64 KB |
| FB | |
| • Number range | 0 ... 65 535 |
| • Size, max. | 512 kbyte |
| FC | |

| | |
|---|--|
| • Number range | 0 ... 65 535 |
| • Size, max. | 512 kbyte |
| OB | |
| • Size, max. | 512 kbyte |
| • Number of free cycle OBs | 100 |
| • Number of time alarm OBs | 20 |
| • Number of delay alarm OBs | 20 |
| • Number of cyclic interrupt OBs | 20; With Failsafe, two RTGs with one "Cyclic interrupt OB" or one "Free cycle OB" (F-OB) each are possible |
| • Number of process alarm OBs | 50 |
| • Number of DPV1 alarm OBs | 3 |
| • Number of isochronous mode OBs | 2 |
| • Number of technology synchronous alarm OBs | 2 |
| • Number of startup OBs | 100 |
| • Number of asynchronous error OBs | 4 |
| • Number of synchronous error OBs | 2 |
| • Number of diagnostic alarm OBs | 1 |
| Nesting depth | |
| • per priority class | 24; Up to 8 possible for F-blocks |
| Counters, timers and their retentivity | |
| S7 counter | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC counter | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| S7 times | |
| • Number | 2 048 |
| Retentivity | |
| — adjustable | Yes |
| IEC timer | |
| • Number | Any (only limited by the main memory) |
| Retentivity | |
| — adjustable | Yes |
| Data areas and their retentivity | |
| Flag | |
| • Number, max. | 16 kbyte |
| • Number of clock memories | 8; 8 clock memory bits, grouped into one clock memory byte |
| Data blocks | |

| | |
|-------------------------------------|---|
| • Retentivity adjustable | Yes |
| • Retentivity preset | No |
| Local data | |
| • per priority class, max. | 64 kbyte; max. 16 KB per block |
| Address area | |
| Number of IO modules | 16 384; max. number of modules / submodules |
| I/O address area | |
| • Inputs | 32 kbyte; All inputs are in the process image |
| • Outputs | 32 kbyte; All outputs are in the process image |
| per integrated IO subsystem | |
| — Inputs (volume) | 16 kbyte; 16 KB via the integrated PROFINET IO interface, 8 KB via the integrated DP interface |
| — Outputs (volume) | 16 kbyte; 16 KB via the integrated PROFINET IO interface, 8 KB via the integrated DP interface |
| per CM/CP | |
| — Inputs (volume) | 8 kbyte |
| — Outputs (volume) | 8 kbyte |
| Subprocess images | |
| • Number of subprocess images, max. | 32 |
| Hardware configuration | |
| Number of distributed IO systems | 64; A distributed I/O system is characterized not only by the integration of distributed I/O via PROFINET or PROFIBUS communication modules, but also by the connection of I/O via AS-i master modules or links (e.g. IE/PB-Link) |
| Number of DP masters | |
| • integrated | 1 |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Number of IO Controllers | |
| • integrated | 2 |
| • Via CM | 8; A maximum of 8 CMs/CPs (PROFIBUS, PROFINET, Ethernet) can be inserted in total |
| Rack | |
| • Modules per rack, max. | 32; CPU + 31 modules |
| • Number of lines, max. | 1 |
| PtP CM | |
| • Number of PtP CMs | the number of connectable PtP CMs is only limited by the number of available slots |
| Time of day | |
| Clock | |
| • Type | Hardware clock |
| • Backup time | 6 wk; At 40 °C ambient temperature, typically |

| | |
|--------------------------------|-----------------|
| • Deviation per day, max. | 10 s; Typ.: 2 s |
| Operating hours counter | |
| • Number | 16 |
| Clock synchronization | |
| • supported | Yes |
| • to DP, master | Yes |
| • in AS, master | Yes |
| • in AS, slave | Yes |
| • on Ethernet via NTP | Yes |

| | |
|-------------------------------|---|
| Interfaces | |
| Number of PROFINET interfaces | 3 |
| Number of PROFIBUS interfaces | 1 |

1. Interface

| | |
|------------------------|---------|
| Interface types | |
| • Number of ports | 2 |
| • integrated switch | Yes |
| • RJ 45 (Ethernet) | Yes; X1 |

| | |
|--------------------------|-----|
| Functionality | |
| • PROFINET IO Controller | Yes |
| • PROFINET IO Device | Yes |
| • SIMATIC communication | Yes |
| • Open IE communication | Yes |
| • Web server | Yes |
| • Media redundancy | Yes |

PROFINET IO Controller

| | |
|---|--|
| Services | |
| — PG/OP communication | Yes |
| — S7 routing | Yes |
| — Isochronous mode | Yes |
| — Open IE communication | Yes |
| — IRT | Yes |
| — MRP | Yes; As MRP redundancy manager and/or MRP client; max. number of devices in the ring: 50 |
| — MRPD | Yes; Requirement: IRT |
| — PROFIenergy | Yes |
| — Prioritized startup | Yes; Max. 32 PROFINET devices |
| — Number of connectable IO Devices, max. | 512; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| — Of which IO devices with IRT, max. | 64 |
| — Number of connectable IO Devices for RT, max. | 512 |

| | |
|---|--|
| — of which in line, max. | 512 |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| — Number of IO Devices per tool, max. | 8 |
| — Updating times | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |

Update time for IRT

| | |
|--|--|
| — for send cycle of 125 μ s | 125 μ s |
| — for send cycle of 187.5 μ s | 187.5 μ s |
| — for send cycle of 250 μ s | 250 μ s to 4 ms |
| — for send cycle of 500 μ s | 500 μ s to 8 ms |
| — for send cycle of 1 ms | 1 ms to 16 ms |
| — for send cycle of 2 ms | 2 ms to 32 ms |
| — for send cycle of 4 ms | 4 ms to 64 ms |
| — With IRT and parameterization of "odd" send cycles | Update time = set "odd" send clock (any multiple of 125 μ s: 375 μ s, 625 μ s ... 3 875 μ s) |

Update time for RT

| | |
|---------------------------------|-----------------------|
| — for send cycle of 250 μ s | 250 μ s to 128 ms |
| — for send cycle of 500 μ s | 500 μ s to 256 ms |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| — for send cycle of 2 ms | 2 ms to 512 ms |
| — for send cycle of 4 ms | 4 ms to 512 ms |

PROFINET IO Device

Services

| | |
|---|-----------------------|
| — PG/OP communication | Yes |
| — S7 routing | Yes |
| — Isochronous mode | No |
| — Open IE communication | Yes |
| — IRT | Yes |
| — MRP | Yes |
| — MRPD | Yes; Requirement: IRT |
| — PROFINergy | Yes |
| — Shared device | Yes |
| — Number of IO Controllers with shared device, max. | 4 |

2. Interface

Interface types

| | |
|---------------------|---------|
| • Number of ports | 1 |
| • integrated switch | No |
| • RJ 45 (Ethernet) | Yes; X2 |

Functionality

| | |
|---|--|
| • PROFINET IO Controller | Yes |
| • PROFINET IO Device | Yes |
| • SIMATIC communication | Yes |
| • Open IE communication | Yes |
| • Web server | Yes |
| • Media redundancy | No |
| PROFINET IO Controller | |
| Services | |
| — PG/OP communication | Yes |
| — S7 routing | Yes |
| — Isochronous mode | No |
| — Open IE communication | Yes |
| — IRT | No |
| — MRP | No |
| — PROFINergy | Yes |
| — Prioritized startup | No |
| — Number of connectable IO Devices, max. | 128; In total, up to 1 000 distributed I/O devices can be connected via AS-i, PROFIBUS or PROFINET |
| — Number of connectable IO Devices for RT, max. | 32 |
| — of which in line, max. | 128 |
| — Number of IO Devices that can be simultaneously activated/deactivated, max. | 8; in total across all interfaces |
| — Updating times | The minimum value of the update time also depends on communication share set for PROFINET IO, on the number of IO devices, and on the quantity of configured user data |
| Update time for RT | |
| — for send cycle of 1 ms | 1 ms to 512 ms |
| PROFINET IO Device | |
| Services | |
| — PG/OP communication | Yes |
| — S7 routing | Yes |
| — Isochronous mode | No |
| — Open IE communication | Yes |
| — IRT | No |
| — MRP | No |
| — MRPD | No |
| — PROFINergy | Yes |
| — Prioritized startup | No |
| — Shared device | Yes |
| — Number of IO Controllers with shared device, max. | 4 |

3. Interface

| Interface types | |
|---------------------|---------|
| • Number of ports | 1 |
| • integrated switch | No |
| • RJ 45 (Ethernet) | Yes; X3 |

| Functionality | |
|--------------------------|-----|
| • PROFINET IO Controller | No |
| • PROFINET IO Device | No |
| • SIMATIC communication | Yes |
| • Open IE communication | Yes |
| • Web server | Yes |

4. Interface

| Interface types | |
|-------------------|---------|
| • Number of ports | 1 |
| • RS 485 | Yes; X4 |

| Functionality | |
|-------------------------|-----|
| • PROFIBUS DP master | Yes |
| • PROFIBUS DP slave | No |
| • SIMATIC communication | Yes |

Interface types

| RJ 45 (Ethernet) | |
|----------------------------------|--|
| • 100 Mbps | Yes |
| • 1000 Mbps | Yes; Only possible at the 3rd PROFINET interface of the CPU 1518 |
| • Autonegotiation | Yes |
| • Autocrossing | Yes |
| • Industrial Ethernet status LED | Yes |

| RS 485 | |
|---------------------------|-----------|
| • Transmission rate, max. | 12 Mbit/s |

Protocols

| Number of connections | |
|---|---|
| • Number of connections, max. | 384; via integrated interfaces of the CPU and connected CPs / CMs |
| • Number of connections reserved for ES/HMI/web | 10 |
| • Number of connections via integrated interfaces | 192 |
| • Number of S7 routing paths | 64; in total, only 16 S7-Routing connections are supported via PROFIBUS |

| SIMATIC communication | |
|-------------------------------|-----|
| • S7 communication, as server | Yes |

| | |
|---|---|
| <ul style="list-style-type: none"> • S7 communication, as client | Yes |
| <ul style="list-style-type: none"> • User data per job, max. | See online help (S7 communication, user data size) |
| Open IE communication | |
| <ul style="list-style-type: none"> • TCP/IP <ul style="list-style-type: none"> — Data length, max. — several passive connections per port, supported | Yes 64 kbyte Yes |
| <ul style="list-style-type: none"> • ISO-on-TCP (RFC1006) <ul style="list-style-type: none"> — Data length, max. | Yes 64 kbyte |
| <ul style="list-style-type: none"> • UDP <ul style="list-style-type: none"> — Data length, max. | Yes 1 472 byte |
| <ul style="list-style-type: none"> • DHCP | No |
| <ul style="list-style-type: none"> • SNMP | Yes |
| <ul style="list-style-type: none"> • DCP | Yes |
| <ul style="list-style-type: none"> • LLDP | Yes |
| Web server | |
| <ul style="list-style-type: none"> • HTTP | Yes; Standard and user-defined pages |
| <ul style="list-style-type: none"> • HTTPS | Yes; Standard and user-defined pages |
| PROFIBUS DP master | |
| <ul style="list-style-type: none"> • Number of connections, max. | 48; for the integrated PROFIBUS DP interface |
| Services | |
| <ul style="list-style-type: none"> — PG/OP communication | Yes |
| <ul style="list-style-type: none"> — S7 routing | Yes |
| <ul style="list-style-type: none"> — Data record routing | Yes |
| <ul style="list-style-type: none"> — Isochronous mode | Yes |
| <ul style="list-style-type: none"> — Equidistance | Yes |
| <ul style="list-style-type: none"> — Activation/deactivation of DP slaves | Yes |
| OPC UA | |
| <ul style="list-style-type: none"> • OPC UA Server <ul style="list-style-type: none"> — Application authentication — Security policies — User authentication | Yes; Data access (read, write, subscribe), runtime license required Yes Available security policies: None, Basic128Rsa15, Basic256Rsa15, Basic256Sha256 "anonymous" or by user name & password |
| Further protocols | |
| <ul style="list-style-type: none"> • MODBUS | Yes; MODBUS TCP |
| Media redundancy | |
| <ul style="list-style-type: none"> • Switchover time on line break, typ. | 200 ms; For MRP, bumpless for MRPD |
| <ul style="list-style-type: none"> • Number of stations in the ring, max. | 50 |
| Isochronous mode | |
| <ul style="list-style-type: none"> • Isochronous operation (application synchronized up to terminal) | Yes; With minimum OB 6x cycle of 125 µs |

| | |
|---|--|
| Equidistance | Yes |
| S7 message functions | |
| Number of login stations for message functions, max. | 32 |
| Block related messages | Yes |
| Number of configurable alarms, max. | 10 000 |
| Number of simultaneously active alarms in alarm pool | |
| • Number of reserved user alarms | 1 000 |
| • Number of reserved alarms for system diagnostics | 200 |
| • Number of reserved alarms for Motion Control technology objects | 160 |
| Test commissioning functions | |
| Joint commission (Team Engineering) | Yes; Parallel online access possible for up to 10 engineering systems |
| Status block | Yes; Up to 16 simultaneously (in total across all ES clients) |
| Single step | No |
| Status/control | |
| • Status/control variable | Yes |
| • Variables | Inputs/outputs, memory bits, DBs, distributed I/Os, timers, counters |
| • Number of variables, max. | |
| — of which status variables, max. | 200; per job |
| — of which control variables, max. | 200; per job |
| Forcing | |
| • Forcing, variables | Peripheral inputs/outputs |
| • Number of variables, max. | 200 |
| Diagnostic buffer | |
| • present | Yes |
| • Number of entries, max. | 3 200 |
| — of which powerfail-proof | 1 000 |
| Traces | |
| • Number of configurable Traces | 8; Up to 512 KB of data per trace are possible |
| Interrupts/diagnostics/status information | |
| Diagnostics indication LED | |
| • RUN/STOP LED | Yes |
| • ERROR LED | Yes |
| • MAINT LED | Yes |
| • Connection display LINK TX/RX | Yes |
| Supported technology objects | |
| Motion Control | Yes; Note: The number of axes affects the cycle time of the PLC program; selection guide via the TIA Selection Tool or SIZER |

| | |
|--|---|
| <ul style="list-style-type: none"> • Number of available Motion Control resources for technology objects (except cam disks) | 10 240 |
| <ul style="list-style-type: none"> • Required Motion Control resources <ul style="list-style-type: none"> — per speed-controlled axis — per positioning axis — per synchronous axis — per external encoder — per output cam — per cam track — per probe | 40 80 160 80 20 160 40 |
| <ul style="list-style-type: none"> • Positioning axis <ul style="list-style-type: none"> — Number of positioning axes at motion control cycle of 4 ms (typical value) — Number of positioning axes at motion control cycle of 8 ms (typical value) | 100; At 40% CPU load due to Motion Control 128; At 40% CPU load due to Motion Control |
| Controller <ul style="list-style-type: none"> • PID_Compact • PID_3Step • PID-Temp | Yes; Universal PID controller with integrated optimization Yes; PID controller with integrated optimization for valves Yes; PID controller with integrated optimization for temperature |
| Counting and measuring <ul style="list-style-type: none"> • High-speed counter | Yes |

Standards, approvals, certificates

| | |
|--|------------|
| Highest safety class achievable in safety mode | |
| Probability of failure (for service life of 20 years and repair time of 100 hours) | |
| — Low demand mode: PFDavg in accordance with SIL3 | < 2.00E-05 |
| — High demand/continuous mode: PFH in accordance with SIL3 | < 1.00E-09 |

Ambient conditions

| | |
|--|--|
| Ambient temperature during operation | |
| • horizontal installation, min. | 0 °C |
| • horizontal installation, max. | 60 °C; Display: 50 °C, at an operating temperature of typically 50 °C, the display is switched off |
| • vertical installation, min. | 0 °C |
| • vertical installation, max. | 40 °C; Display: 40 °C, at an operating temperature of typically 40 °C, the display is switched off |
| Ambient temperature during storage/transportation | |
| • min. | -40 °C |
| • max. | 70 °C |

Configuration

| | |
|----------------------|--|
| Programming | |
| Programming language | |

| | |
|---|-------------------------------|
| — LAD | Yes; incl. failsafe |
| — FBD | Yes; incl. failsafe |
| — STL | Yes |
| — SCL | Yes |
| — GRAPH | Yes |
| Know-how protection | |
| • User program protection | Yes |
| • Copy protection | Yes |
| • Block protection | Yes |
| Access protection | |
| • Password for display | Yes |
| • Protection level: Write protection | Yes |
| • Protection level: Read/write protection | Yes |
| • Protection level: Complete protection | Yes |
| Cycle time monitoring | |
| • lower limit | adjustable minimum cycle time |
| • upper limit | adjustable maximum cycle time |
| Open Development interfaces | |
| • Size of ODK SO file, max. | 6 Mbyte |
| Dimensions | |
| Width | 175 mm |
| Height | 147 mm |
| Depth | 129 mm |
| Weights | |
| Weight, approx. | 1 988 g |
| last modified: | 12/06/2016 |